



December 13, 2017

Steven Lee
Alameda Unified School District MOF
2060 Challenger Drive
Alameda, CA 94501

transmitted via email to stlee@alameda.k12.ca.us

Re: **Drinking Water Lead Sampling Results**
Alameda Unified School District (AUSD) – Haight Elementary School Drinking Fountains
2025 Santa Clara Ave, Alameda, CA
ACC Project No. 3007-119.00

Dear Mr. Lee:

Enclosed please find the laboratory test results for the drinking water sampling performed at the above-referenced site on November 10, 2017. The sampling was performed to determine lead concentrations in drinking water at drinking fountain locations throughout the school.

The intent of the testing was to collect drinking water samples to determine if lead concentrations at drinking water locations exceed the EPA and California Lead Action Levels. The EPA and State of California Lead Action Levels for lead in drinking water are concentrations exceeding 15 parts per billion (ppb). ACC collected drinking water samples from thirty-six (36) locations at the school. At each location, ACC collected water samples as “first-draw” and “post-flush” samples. First-draw samples were collected after non-use for a minimum of eight (8) continuous hours. Post-flush samples were collected after running the tap for at least thirty (30) seconds. The samples were collected in 125 milliliter bottles preserved with nitric acid and were submitted under standard chain of custody protocols to Forensic Analytical of Hayward, California, an American Industrial Hygiene Association (AIHA) accredited laboratory, for analysis. Samples were analyzed for lead in accordance with the EPA SM3113B Test Method.

ACC collected a total of 72 drinking water samples at 36 drinking fountain locations for analysis. Copies of the laboratory results are attached.

Drinking Water Sample Results

The water samples were obtained from drinking fountain locations as listed herein. The sample numbers, locations, type of draw and lead concentrations are listed below. ACC collected drinking water samples from the main drinking water sources. Not all water sources were sampled.

Sample Number	Location	Type of Draw	Lead Concentration in Parts Per Billion (PPB)
WS-215-FD	Main Office Kitchenette	First Draw	<5
WS-215-PF		Post-Flush	<5
WS-216-FD	Health Office	First Draw	<5
WS-216-PF		Post-Flush	<5
WS-217-FD	Room 10	First Draw	<5
WS-217-PF		Post-Flush	<5
WS-218-FD	Room 11	First Draw	<5
WS-218-PF		Post-Flush	<5
WS-219-FD	Room 9	First Draw	<5
WS-219-PF		Post-Flush	<5
WS-220-FD	Room 12-B	First Draw	<5
WS-220-PF		Post-Flush	<5
WS-221-FD	Room 13	First Draw	<5
WS-221-PF		Post-Flush	<5
WS-222-FD	Room 5 (Silver Fountain at Silver Sink)	First Draw	<5
WS-222-PF		Post-Flush	<5
WS-223-FD	Room 5 (Silver Fountain at White Sink)	First Draw	<5
WS-223-PF		Post-Flush	<5
WS-224-FD	Room 4	First Draw	<5
WS-224-PF		Post-Flush	<5
WS-225-FD	Room 3	First Draw	<5
WS-225-PF		Post-Flush	<5
WS-226-FD	Room 6	First Draw	<5
WS-226-PF		Post-Flush	<5
WS-227-FD	Room 2	First Draw	<5
WS-227-PF		Post-Flush	<5
WS-228-FD	Room 7	First Draw	<5
WS-228-PF		Post-Flush	<5
WS-229-FD	Room 1	First Draw	<5
WS-229-PF		Post-Flush	<5
WS-230-FD	1st Floor Hallway adjacent to South Office Entrance	First Draw	19
WS-230-PF		Post-Flush	<5
WS-231-FD	2 nd Floor Hallway adjacent to Room 19 Entrance	First Draw	<5
WS-231-PF		Post-Flush	<5
WS-232-FD	Room 19	First Draw	<5
WS-232-PF		Post-Flush	<5

Sample Number	Location	Type of Draw	Lead Concentration in Parts Per Billion (PPB)
WS-233-FD	Room 21	First Draw	<5
WS-233-PF		Post-Flush	<5
WS-234-FD	Room 22	First Draw	<5
WS-234-PF		Post-Flush	<5
WS-235-FD	Room 23	First Draw	<5
WS-235-PF		Post-Flush	<5
WS-236-FD	Room 24	First Draw	<5
WS-236-PF		Post-Flush	<5
WS-237-FD	2 nd Floor Faculty Room	First Draw	<5
WS-237-PF		Post-Flush	<5
WS-238-FD	2 nd Floor Hallway across from Staircase 3 Entrance	First Draw	<5
WS-238-PF		Post-Flush	<5
WS-239-FD	Room 14	First Draw	<5
WS-239-PF		Post-Flush	<5
WS-240-FD	Room 15	First Draw	<5
WS-240-PF		Post-Flush	<5
WS-241-FD	Room 17	First Draw	<5
WS-241-PF		Post-Flush	<5
WS-242-FD	Room 16	First Draw	<5
WS-242-PF		Post-Flush	<5
WS-243-FD	Room 28	First Draw	<5
WS-243-PF		Post-Flush	<5
WS-244-FD	Room 27	First Draw	<5
WS-244-PF		Post-Flush	<5
WS-245-FD	Room 26	First Draw	<5
WS-245-PF		Post-Flush	<5
WS-246-FD	Room 25	First Draw	<5
WS-246-PF		Post-Flush	<5
WS-247-FD	North West Building Exterior Wall Fountain between Boiler Room and Boys Restroom	First Draw	<5
WS-247-PF		Post-Flush	<5
WS-248-FD	1 st Floor across from Staircase 3 Entrance	First Draw	<5
WS-248-PF		Post-Flush	<5
WS-249-FD	Multi-Purpose Room Northwest Wall	First Draw	<5
WS-249-PF		Post-Flush	<5
WS-250-FD	Outdoors Southeast Exterior of Multi-Purpose Room Building between Girls Restroom and Storage Room	First Draw	<5
WS-250-PF		Post-Flush	<5

One of the first-draw water sample concentrations at the '1st Floor Hallway adjacent to South Office Entrance' Drinking Fountain was above the EPA and California Lead Action Level of 15 PPB. When the first-draw and post-flush samples are both elevated this may indicate leaching of lead from the fixture and distribution water lines in the building. When the pre-flush only is elevated, this usually indicates localized corrosion issues within the faucet, fittings and/or connections.

The EPA and California Lead Action Levels are used to protect the public from metals that can adversely affect their health. These laws require water systems to monitor lead levels at the consumers' taps. If Action Levels for lead (15 ppb) are exceeded, installation or modifications to corrosion control treatment is required. In addition, if the action level for lead is exceeded, public notification is required.

Recommendations

Based on the results of the drinking water investigation, ACC makes the following recommendations:

- ACC recommends disconnecting/replacing the fixture at the '1st Floor Hallway adjacent to South Office Entrance' Drinking Fountain location where the first-draw water sampling concentration exceeded the action level and subsequent re-sampling at this location.

Limitations

ACC shall not be responsible for claims that may arise out of failure to correct problems or to identify problems that may exist at this location. ACC assumes no responsibility for damages for work performed or errors in documentation or missing information. ACC does not guarantee the accuracy of information provided by other parties. All statements and/or recommendations are based on conditions observed and tested at the time of the inspection. The scope of the investigation for this report was to collect representative drinking water samples from several locations at the school. ACC has not investigated and does not possess any opinion regarding other drinking water locations within the building. This report does not intend to identify all hazards or unsafe conditions, or to indicate that other hazards or unsafe conditions do not exist at the subject site.


Please contact me at (510) 638-8400 ext. 109 if you have any questions.

Sincerely,

ACC ENVIRONMENTAL CONSULTANTS, INC.



Ben Schulte-Bisping
Project Manager
California Department of Public Health Lead I/A/M #24564



Mark A. Sanchez, CHMM
President
California Department of Public Health Lead I/A/M/S #5150

Attachments: Forensic Analytical Metals Analysis of Drinking Water Report #M191732, dated 12/01/17.

Metals Analysis of Drinking Water

ACC Environmental Consultants

Ben Schulte Bisping

7977 Capwell Dr., Suite 100

Oakland, CA 94621

Client ID: 1117

Report Number: M191732

Date Received: 11/16/17

Date Analyzed: 12/01/17

Date Printed: 12/01/17

First Reported: 12/01/17

Job ID / Site: 3007-119.00, AUSD Water Sampling, Haight ES, 2025 Santa Clara Ave.

Date(s) Collected: 11/10/17

FALI Job ID: 1117-1506

Total Samples Submitted: 72

Total Samples Analyzed: 72

Sample Number	Lab Number	Analyte	Result	Result Units	Reporting Limit*	Method Reference
WS-215-FD	30785147	Pb	< 5	ppb	5	SM 3113B
WS-215-PF	30785148	Pb	< 5	ppb	5	SM 3113B
WS-216-FD	30785149	Pb	< 5	ppb	5	SM 3113B
WS-216-PF	30785150	Pb	< 5	ppb	5	SM 3113B
WS-217-FD	30785151	Pb	< 5	ppb	5	SM 3113B
WS-217-PF	30785152	Pb	< 5	ppb	5	SM 3113B
WS-218-FD	30785153	Pb	< 5	ppb	5	SM 3113B
WS-218-PF	30785154	Pb	< 5	ppb	5	SM 3113B
WS-219-FD	30785155	Pb	< 5	ppb	5	SM 3113B
WS-219-PF	30785156	Pb	< 5	ppb	5	SM 3113B
WS-220-FD	30785157	Pb	< 5	ppb	5	SM 3113B
WS-220-PF	30785158	Pb	< 5	ppb	5	SM 3113B
WS-221-FD	30785159	Pb	< 5	ppb	5	SM 3113B
WS-221-PF	30785160	Pb	< 5	ppb	5	SM 3113B
WS-222-FD	30785161	Pb	< 5	ppb	5	SM 3113B
WS-222-PF	30785162	Pb	< 5	ppb	5	SM 3113B
WS-223-FD	30785163	Pb	< 5	ppb	5	SM 3113B
WS-223-PF	30785164	Pb	< 5	ppb	5	SM 3113B
WS-224-FD	30785165	Pb	< 5	ppb	5	SM 3113B
WS-224-PF	30785166	Pb	< 5	ppb	5	SM 3113B
WS-225-FD	30785167	Pb	< 5	ppb	5	SM 3113B
WS-225-PF	30785168	Pb	< 5	ppb	5	SM 3113B
WS-226-FD	30785169	Pb	< 5	ppb	5	SM 3113B
WS-226-PF	30785170	Pb	< 5	ppb	5	SM 3113B
WS-227-FD	30785171	Pb	< 5	ppb	5	SM 3113B
WS-227-PF	30785172	Pb	< 5	ppb	5	SM 3113B
WS-228-FD	30785173	Pb	< 5	ppb	5	SM 3113B

Metals Analysis of Drinking Water

ACC Environmental Consultants

Ben Schulte Bisping

7977 Capwell Dr., Suite 100

Oakland, CA 94621

Client ID: 1117

Report Number: M191732

Date Received: 11/16/17

Date Analyzed: 12/01/17

Date Printed: 12/01/17

First Reported: 12/01/17

Job ID / Site: 3007-119.00, AUSD Water Sampling, Haight ES, 2025 Santa Clara Ave.

Date(s) Collected: 11/10/17

FALI Job ID: 1117-1506

Total Samples Submitted: 72

Total Samples Analyzed: 72

Sample Number	Lab Number	Analyte	Result	Result Units	Reporting Limit*	Method Reference
WS-228-PF	30785174	Pb	< 5	ppb	5	SM 3113B
WS-229-FD	30785175	Pb	< 5	ppb	5	SM 3113B
WS-229-PF	30785176	Pb	< 5	ppb	5	SM 3113B
WS-230-FD	30785177	Pb	19	ppb	5	SM 3113B
WS-230-PF	30785178	Pb	< 5	ppb	5	SM 3113B
WS-231-FD	30785179	Pb	< 5	ppb	5	SM 3113B
WS-231-PF	30785180	Pb	< 5	ppb	5	SM 3113B
WS-232-FD	30785181	Pb	< 5	ppb	5	SM 3113B
WS-232-PF	30785182	Pb	< 5	ppb	5	SM 3113B
WS-233-FD	30785183	Pb	< 5	ppb	5	SM 3113B
WS-233-PF	30785184	Pb	< 5	ppb	5	SM 3113B
WS-234-FD	30785185	Pb	< 5	ppb	5	SM 3113B
WS-234-PF	30785186	Pb	< 5	ppb	5	SM 3113B
WS-235-FD	30785187	Pb	< 5	ppb	5	SM 3113B
WS-235-PF	30785188	Pb	< 5	ppb	5	SM 3113B
WS-236-FD	30785189	Pb	< 5	ppb	5	SM 3113B
WS-236-PF	30785190	Pb	< 5	ppb	5	SM 3113B
WS-237-FD	30785191	Pb	< 5	ppb	5	SM 3113B
WS-237-PF	30785192	Pb	< 5	ppb	5	SM 3113B
WS-238-FD	30785193	Pb	< 5	ppb	5	SM 3113B
WS-238-PF	30785194	Pb	< 5	ppb	5	SM 3113B
WS-239-FD	30785195	Pb	< 5	ppb	5	SM 3113B
WS-239-PF	30785196	Pb	< 5	ppb	5	SM 3113B
WS-240-FD	30785197	Pb	< 5	ppb	5	SM 3113B
WS-240-PF	30785198	Pb	< 5	ppb	5	SM 3113B
WS-241-FD	30785199	Pb	< 5	ppb	5	SM 3113B
WS-241-PF	30785200	Pb	< 5	ppb	5	SM 3113B



Metals Analysis of Drinking Water

ACC Environmental Consultants

Ben Schulte Bisping

7977 Capwell Dr., Suite 100

Oakland, CA 94621

Client ID: 1117

Report Number: M191732

Date Received: 11/16/17

Date Analyzed: 12/01/17

Date Printed: 12/01/17

First Reported: 12/01/17

Job ID / Site: 3007-119.00, AUSD Water Sampling, Haight ES, 2025 Santa Clara Ave.

Date(s) Collected: 11/10/17

FALI Job ID: 1117-1506

Total Samples Submitted: 72

Total Samples Analyzed: 72

Sample Number	Lab Number	Analyte	Result	Result Units	Reporting Limit*	Method Reference
WS-242-FD	30785201	Pb	< 5	ppb	5	SM 3113B
WS-242-PF	30785202	Pb	< 5	ppb	5	SM 3113B
WS-243-FD	30785203	Pb	< 5	ppb	5	SM 3113B
WS-243-PF	30785204	Pb	< 5	ppb	5	SM 3113B
WS-244-FD	30785205	Pb	< 5	ppb	5	SM 3113B
WS-244-PF	30785206	Pb	< 5	ppb	5	SM 3113B
WS-245-FD	30785207	Pb	< 5	ppb	5	SM 3113B
WS-245-PF	30785208	Pb	< 5	ppb	5	SM 3113B
WS-246-FD	30785209	Pb	< 5	ppb	5	SM 3113B
WS-246-PF	30785210	Pb	< 5	ppb	5	SM 3113B
WS-247-FD	30785211	Pb	< 5	ppb	5	SM 3113B
WS-247-PF	30785212	Pb	< 5	ppb	5	SM 3113B
WS-248-FD	30785213	Pb	< 5	ppb	5	SM 3113B
WS-248-PF	30785214	Pb	< 5	ppb	5	SM 3113B
WS-249-FD	30785215	Pb	< 5	ppb	5	SM 3113B
WS-249-PF	30785216	Pb	< 5	ppb	5	SM 3113B
WS-250-FD	30785217	Pb	< 5	ppb	5	SM 3113B
WS-250-PF	30785218	Pb	< 5	ppb	5	SM 3113B


* The Reporting Limit represents the lowest amount of analyte that the laboratory can confidently detect in the sample, and is not a regulatory level. The Units for the Reporting Limit are the same as the Units for the Final Results.

Daniele Siu

Daniele Siu, Laboratory Supervisor, Hayward Laboratory

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. Any modifications that have been made to referenced test methods are documented in Forensic Analytical's Standard Operating Procedures Manual. Quality control and sample receipt condition were acceptable unless otherwise noted.

BULK SAMPLE CHAIN-OF-CUSTODY


Report to:	Ben Schulte Bisping		Email:	Bshulte@accenv.com	Phone:	510.773.0708	
Project Name:	AUSD Water Sampling						
Project Address:	Haight Elementary School, 2025 Santa Clara Ave				Project Number:	3007-119.00	
Collected by:	Gus Valerian				Date Collected:	11/10/2017	
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer		Turnaround Time: 5 Day	
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA						
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size			
WS-215-FD	POTABLE WATER- FIRST DRAW	Main Office, Kitchenette	Silver faucet Note: drinking Cups adjacent to sink				
WS-215-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
WS-216-FD	POTABLE WATER- FIRST DRAW	Health office	Silver fountain, right (cold) lever Note: drinking cups adjacent to sink				
WS-216-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
WS-217-FD	POTABLE WATER- FIRST DRAW	Room 10	Fountain				
WS-217-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
WS-218-FD	POTABLE WATER- FIRST DRAW	Room 11	Fountain				
WS-218-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
WS-219-FD	POTABLE WATER- FIRST DRAW	Room 9	Fountain				
WS-219-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
WS-220-FD	POTABLE WATER- FIRST DRAW	Room 12-B	Fountain				
WS-220-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE				
Released:	Signature:		Date:	Time:			
Received:	Signature:		Date:	Time:			
							
Lab Info:	EMSE Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 <input checked="" type="checkbox"/> Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828						

BULK SAMPLE CHAIN-OF-CUSTODY

Report to:	Ben Schulte Bisping		Email:	Bshulte@accenv.com		Phone:	510.773.0708	
Project Name:	AUSD Water Sampling							
Project Address:	Haight Elementary School, 2025 Santa Clara Ave					Project Number:	3007-119.00	
Collected by:	Gus Valerian					Date Collected:	11/10/2017	
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer		Turnaround Time:	5 Day	
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA							
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size				
WS-221-FD	POTABLE WATER- FIRST DRAW	Room 13	Fountain					
WS-221-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-222-FD	POTABLE WATER- FIRST DRAW	Room 5	Silver Fountain w/ silver sink					
WS-222-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-223-FD	POTABLE WATER- FIRST DRAW	Room 5	Silver fountain with white sink					
WS-223-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-224-FD	POTABLE WATER- FIRST DRAW	Room 4	Fountain					
WS-224-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-225-FD	POTABLE WATER- FIRST DRAW	Room 3	Fountain					
WS-225-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-226-FD	POTABLE WATER- FIRST DRAW	Room 6	Fountain					
WS-226-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
Released:	Signature:		Date:	Time:				
Received:	Signature:		Date:	Time:				
								
Lab Info:	EMSL Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828							

BULK SAMPLE CHAIN-OF-CUSTODY

Report to:	Ben Schulte Bisping	Email:	Bshulte@accenv.com	Phone:	510.773.0708
Project Name:	AUSD Water Sampling				
Project Address:	Haight Elementary School, 2025 Santa Clara Ave			Project Number:	3007-119.00
Collected by:	Gus Valerian			Date Collected:	11/10/2017
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer	Turnaround Time: 5 Day
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA				
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size	
WS-227-FD	POTABLE WATER- FIRST DRAW	Room 2	Dual sink/ Fountain combos, South East fountain tested		
WS-227-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-228-FD	POTABLE WATER- FIRST DRAW	Room 7	Fountain		
WS-228-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-229-FD	POTABLE WATER- FIRST DRAW	Room 1	Dual sink/ Fountain combos, South East fountain tested		
WS-229-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-230-FD	POTABLE WATER- FIRST DRAW	1st floor Hallway , adjacent to south office entrance	Silver fountain		
WS-230-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-231-FD	POTABLE WATER- FIRST DRAW	2nd floor hallway, adjacent to room 19 entrance	Silver fountain		
WS-231-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-232-FD	POTABLE WATER- FIRST DRAW	Room 19	Fountain		
WS-232-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
Released:	Signature:		Date:	Time:	
Received:	Signature:		Date:	Time:	
Lab Info:	EMSL Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828				




BULK SAMPLE CHAIN-OF-CUSTODY

Report to:	Ben Schulte Bisping	Email:	Bshulte@accenv.com	Phone:	510.773.0708
Project Name:	AUSD Water Sampling				
Project Address:	Haight Elementary School, 2025 Santa Clara Ave			Project Number:	3007-119.00
Collected by:	Gus Valerian			Date Collected:	11/10/2017
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer	Turnaround Time: 5 Day
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA				
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size	
WS-233-FD	POTABLE WATER- FIRST DRAW	Room 21	Fountain		
WS-233-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-234-FD	POTABLE WATER- FIRST DRAW	Room 22	Fountain		
WS-234-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-235-FD	POTABLE WATER- FIRST DRAW	Room 23	Fountain		
WS-235-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-236-FD	POTABLE WATER- FIRST DRAW	Room 24	Fountain		
WS-236-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-237-FD	POTABLE WATER- FIRST DRAW	2nd floor faculty room	Silver faucet, right side lever Note: cups adjacent to sink		
WS-237-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-238-FD	POTABLE WATER- FIRST DRAW	2nd floor hallway, across from stair case 3 entrance	Silver fountain		
WS-238-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
Released:	Signature:		Date:	Time:	
Received:	Signature:		Date:	Time:	
					
Lab Info:	EMSL Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 <input checked="" type="checkbox"/> Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828				

BULK SAMPLE CHAIN-OF-CUSTODY

Report to:	Ben Schulte Bisping	Email:	Bshulte@accenv.com	Phone:	510.773.0708
Project Name:	AUSD Water Sampling				
Project Address:	Haight Elementary School, 2025 Santa Clara Ave			Project Number:	3007-119.00
Collected by:	Gus Valerian			Date Collected:	11/10/2017
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer	Turnaround Time: 5 Day
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA				
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size	
WS-239-FD	POTABLE WATER- FIRST DRAW	Room 14	Fountain		
WS-239-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-240-FD	POTABLE WATER- FIRST DRAW	Room 15	Fountain		
WS-240-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-241-FD	POTABLE WATER- FIRST DRAW	Room 17	Fountain		
WS-241-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-242-FD	POTABLE WATER- FIRST DRAW	Room 16	Fountain		
WS-242-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-243-FD	POTABLE WATER- FIRST DRAW	Room 28	Fountain		
WS-243-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
WS-244-FD	POTABLE WATER- FIRST DRAW	Room 27	Fountain		
WS-244-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE		
Released:	Signature:		Date:	Time:	
Received:	Signature:		Date:	Time:	
Lab Info:	 EMSL Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828				

BULK SAMPLE CHAIN-OF-CUSTODY

Report to:	Ben Schulte Bisping		Email:	Bshulte@accenv.com		Phone:	510.773.0708	
Project Name:	AUSD Water Sampling							
Project Address:	Haight Elementary School, 2025 Santa Clara Ave					Project Number:	3007-119.00	
Collected by:	Gus Valerian					Date Collected:	11/10/2017	
Sample Analysis:	PLM	<input checked="" type="checkbox"/> Lead	GFAA	Stop at 1 st Positive Layer		Turnaround Time:	5 Day	
Comments:	ANALYZE WATER SAMPLES FOR LEAD VIA GFAA							
Sample ID	Material Size-Color-Pattern-Material-Post Description	Material Location [Quantity] Building or Floor: Area(s) - Component	Sample Location Area - Component	Size				
WS-245-FD	POTABLE WATER- FIRST DRAW	Room 26	Fountain					
WS-245-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-246-FD	POTABLE WATER- FIRST DRAW	Room 25	Fountain					
WS-246-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-247-FD	POTABLE WATER- FIRST DRAW	North West building Exterior wall Fountain, between boiler room and boys restroom	Dual silver fountains, right side					
WS-247-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-248-FD	POTABLE WATER- FIRST DRAW	1st floor, across from stair case #3 entrance	Dual silver fountains, right side					
WS-248-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-249-FD	POTABLE WATER- FIRST DRAW	Multi purpose room, NW wall	Silver fountain					
WS-249-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
WS-250-FD	POTABLE WATER- FIRST DRAW	Outdoor, SE exterior of multi purpose room building, between girls RR and storage room	Dual silver fountains, right side					
WS-250-PF	POTABLE WATER- POST FLUSH	SAME AS ABOVE	SAME AS ABOVE					
Released:	Signature:		Date:	Time:				
Received:	Signature:		Date:	Time:				
								
Lab Info:	EMSL Analytical, Inc. (EMSL): 464 McCormick Street, San Leandro, California 94577, (510) 895-3675 Forensic Analytical Laboratories, Inc. (FALI): 3777 Depot Road # 409, Hayward, California 94545, (510) 887-8828							